


























Tempstar Split System Comparison	MAINLINE MODELS			PERFORMANCE MODELS	
	TX 5300	TX 5500/ TX 5600	TXT+	13	15/16
HP MODEL SERIES	T4H3	TXH5	T4H5/ T4H7	N4H3	NXH5
AC MODEL SERIES	T4A3	TXA6	T4A6/ T4A8	N4A3	NXA6
REFRIGERANT	 R410A	 R410A	 R410A	 R410A	 R410A
SEER RATING*	13	 15/Up to 16 [†]	 15-18	13	 15/Up to 16 [†]
HSPF RATING* Heat Pumps Only	7.7	8.5	8.5	7.7	8.5
NO HASSLE REPLACEMENT™ Limited Warranty	1 YR	5 YR	10 YR		
PARTS & COMPRESSOR Limited Warranty [‡]	10 YR	10 YR	10 YR	10 YR	10 YR
COMPRESSOR *Also includes sound jacket	Scroll*	Scroll*	Scroll*	Scroll	Scroll
TWO-STAGE COMPRESSOR					
COMFORT ALERT® Diagnostic System					
ENHANCED AIR MANAGEMENT					

[†] Proper sizing and installation of equipment is critical to achieve optimal performance. Split system air conditioners and heat pumps must be matched with appropriate coil components to meet ENERGY STAR® criteria. Ask your contractor for details or visit www.energystar.gov.

[♦] For information regarding furnace or fan coil options that can increase the energy efficiency of selected 13 and 14 SEER Tempstar air conditioners (SEER) and heat pumps (SEER and HSPF), go to Tempstar.com and look for “Energy Savings” on the menu.

[‡] Timely registration required for 10 year parts limited warranty. Limited warranty period is 5 years for parts if not registered within 90 days of installation. Jurisdictions where warranty benefits cannot be conditioned on registration will receive the registered limited warranty periods. Please see warranty certificate for further details and restrictions.

[†] 16 SEER rating when when paired with select indoor equipment.